



MUNICIPAL CORPORATION CHANDIGARH

(Public Health Laboratory at Water Works Sector - 39)

TEST - REPORT

Not for legal use

Lab No.: MCPHL/26/ 1355

Date : 15.05.2026


Ref. No. : GMHS/36D/2026/278	Sample Details	Date & Time
Dated : 11.05.2026		
Issued to : The Headmistress Govt. Model High School, Sector - 36,D, Chandigarh,	Collected By	Laboratory Staff
Location : From School tap of Govt. Model High School, Sector - 36,D, Chandigarh,	Collection Date	11.05.2026 06:45 p.m.
Packing : Polypropylene and glass bottle	Received at Lab	08:00 a.m.


Test Result (As Per BIS 10500:2012)

S.No	Examination	Quality Standard	Unit	Result
1	pH	6.5 - 8.5	---	7.74
2	Odour	Agreeable	---	Agreeable
3	Taste	Agreeable	---	Agreeable
4	Turbidity	<1	N.T.U.	0.9
5	Total Dissolved Solids	<500	mg/l	149
6	Residual Chlorine	0.2 - 0.4	mg/l	0.3
7	Total Alkalinity (as CaCO ₃)	<200	mg/l	102
8	Total Hardness (as CaCO ₃)	<200	mg/l	98
9	Chlorides (as Cl)	<250	mg/l	04
10	Free & Saline Ammonia	NIL	mg/l	NIL
11	M.P.N. of Coliform Bacilli / 100ml of water	Zero	M.P.N.	0 (Excellent)

Payment received vide receipt No. 05/2026-27/318734, dated 11.05.2026, amount Rs. - 3300/-

Note: - Water sample is found "POTABLE".



Chemist,
M.C.P.H. Laboratory,
Chandigarh.



Sub Divisional Engineer,
M.C.P.H. Sub Division No.1,
Chandigarh.

Endst. No. MCPH/26/-----

Dated : 15.05.2026

Copy forwarded to the Medical Officer of Health Municipal Corporation, Sector -17, Chandigarh for Information please.


Chemist,
M.C.P.H. Laboratory,
Chandigarh.


Sub Divisional Engineer,
M.C.P.H. Sub Division No.1,
Chandigarh.

Remarks:-

- The results given above are related to the sample as collected and tested in lab.
- The test report can't be regenerated in whole or part there of without written permission of Competent Authority.
- The test report can't be used for any publicity or legal purpose.

----- End of Report -----

WATER IS LIFE, SAVE IT